



May 4, 2019
DVP-190008

Mr. David Jones
Air Pollution Control Officer
South Coast Air Quality Management District
21865 East Copley Drive
Diamond Bar, California 91765-4182

Subject: Monthly Report of Excess Emissions for April 2019

SCAQMD FILE # 100154

Dear Mr. Jones:

Excess emissions summaries for each boiler for April 2019 are attached.

Emission concentration limits (ppm) do not apply during the normal start up and shut down conditions for each boiler. Thus, exceedances within the permit limits during start up and shut down, as defined in the amendment, are not applicable and as such not reportable.

Please call if you have any questions or comments. I can be reached at (760) 262-1653.

Sincerely,

A handwritten signature in black ink, appearing to read "James Russell Huffman".

James Russell Huffman

Vice President of CA Operations / Plant Manager



Page 2

encl

cc:

Chief, Stationary Source Division

California Air Resources Board

P.O. Box 2815

Sacramento, CA 95814

Director, Air Management Division

Attention: Air-5

U.S. Environmental Protection Agency

75 Hawthorne Street

San Francisco, CA 94105-3901

BOILER #1
April 2019

[illegible]

1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

BOILER #2
April 2019

[illegible]

1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

STACK
April 2019

[illegible]

1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)